

EC certificate of conformity

0085-CPD-BU0355

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Product Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product.

KALDE 14800; 701.150.....000

Safety gas hose line with wall plug

and manufactured by

Kalde Klima Orta Basınç Fittings ve Valf Sanayi A.S.
Adnan Kahveci mah.Buyukd. cad.no:20, TR-34524 Beylikdüzü-Istanbul

and manufactured by

Haci Ayvaz End. Mamüller San.ve Tic. A.S
Atatürk San.Bolg. Inan Cad. No. 36
TR-34860 Hadimköy / Istanbul

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body - DVGW CERT GmbH - has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performance described in the Annex ZA of the standard

DIN EN 14800 (Juni 2007)

were applied and that the product fulfills all the prescribed requirements.

This certificate remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

The first issue of the certificate was on 21.01.2010

The actual application number is 12-0474-GBR

20.07.2012 K6 E-1/2

Date issued by Head of Certification Body
Datum, Bescheiniger, Datum, Leiter der Zertifizierungsstelle

DVGW CERT GmbH - recognized by the German Institute for Building Technology (DIBt) and notified at the European Commission as certification body for the EC Construction Products Directive

DVGW CERT GmbH - vom Deutschen Institut für Bautechnik (DIBt) anerkannt und bei der Europäischen Kommission benannte Zertifizierungsstelle für die Bauproduktenrichtlinie

DIBt
ZP 42

DVGW CERT GmbH
Josef-Wirmer-Straße 1-3
53123 Bonn

Telefon: +49 228 91 88-888
Telefax: +49 228 91 88-993
eMail: info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
KALDE 14800	: d0 : bestanden : B : 0,177 Ohm/m : 500, 750, 1000, 1250, 1500, 2000 mm nominal diameter: DN 12 : s2 : bis 650°C gem. DIN EN 1775:02/2001 für 30 min : 1000 N max. operating pressure: 500 mbar	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
KALDE 14800; 701.150.151.000	Connection: swivel nut G 1/2 acc. DIN EN 228-1 (pic. A.10) and conical thread acc. DIN EN 10226-1 (pic. A.8)
KALDE 14800; 701.150.152.000	Connection: swivel nut G 1/2 acc. DIN EN 228-1 (pic. A.10) and thread G 1/2 acc. DIN EN 228-1
KALDE 14800; 701.150.153.000	Connection: Rp 1/2 (pic. A.18) and DN 12 (pic. A.4)
KALDE 14800; 701.150.154.000	Connection: connection plug DN 12 (pic. A.7) and conical thread acc. DIN EN 10226-1 (pic. A.8)
KALDE 14800; 701.150.158.000	Connection: thread Rp 1/2 (pic. A.18) and connection plug DN 12 (pic. A.3)
KALDE 14800; 701.150.159.000	Connection: swivel nut G 1/2 acc. DIN EN 228-1 (pic. A.10) and connection plug DN 12 (pic. A.3)
KALDE 14800; 701.150.160.000	Connection: swivel nut G 1/2 acc. DIN EN 228-1 (pic. A.10) and thread Rp 1/2 (pic. A.18)

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

Relevant test reports:

Type testing: B 12/07/15055 dated 02.07.2012 and B 11/01/1317 dated 19.01.2011, DBI Freiberg

Fire behavior: 2009-B-2529/01; .../02; .../03 dated 29.07.2009, MPA Dresden

Production control: FPC Report No. 30-10549 dated 17.12.2009, SZU Brno